

SWEDISH TECHNICAL APPROVAL

0790/91

The product described below and production control has been found to comply with Building Regulations of the National Board of Housing Building and Planning (BBR) with reference to and under conditions described in this approval.

Aquatron, sewage separator

Holder	Aquatron International AB, Norrängsgatan 10, 725 91 Västerås. Tel: 021-560 20, VAT number: 556886-7054. E-mail: info@aquatron.se Internet: www.aquatron.se	
Product	Aquatron sewage separator is a separator without movable parts there feces and paper are separated from sewage water. The separator should be placed on top of a bio composting chamber that is intended to handle the volume of solids. Liquid from the separator shall be directed to municipal or private facility that is designed to handle this type of liquid.	
Intended use	Sewage separator is intended to be installed after the water closet for separating solids from liquids.	
Trade name	Aquatron sewage separator	
Approval	The products have been found to meet the requirements in the following sections of the Building Regulations of the National Board of Housing, Building and Planning (BBR): Waste water installations 6:641, 1 st sentence Design 6:644, 1 st sentence	
Associated documents	Installation instruction 100, 200 and 300, dated 2012-02-17 by SP SITAC. Installation instruction 50, 90 and 400, dated 2012-02-17 by SP SITAC.	
Control	Production control is to be performed in accordance with instructions for control dated 16 June 2012. An independent inspection body audits the control. Control agreement: 210-12-0133. Inspection body: SP technical Research Institute of Sweden.	

Control (cont.)	When the building proprietor performs inspection at the building site, he shall check the markings to ensure that the correct products have been supplied and that they are used in accordance with the requirements stated in the approval and the associated documents.
Manufacturer	Production control includes the following site: Cipax AB, Skebobruk.
Marking	The products are to be marked at the factory. The marking consists of a label on every product supplied and includes: Approval holder Aquatron International AB P-mark P Certification body SP SITAC Approval number 0790/91 Product type designation Aquatron avloppsseparator Consecutive manufacture date of production date Inspection body SP
Basis for approval	Report E30314 from SP technical Research Institute of Sweden.
Comments	In this approval are only properties for separation evaluated. This approval supersedes the previous certificate with the same number dated 25 April 2005 with project number T500045.
Period of validity	This approval is valid until 13 September 2017.



Ingvar Pettersson



Marcus Tillman